

**To:** [Ex. 6 - Personal Privacy]@a [Ex. 6 - Personal Privacy]amwater.com]  
**Cc:** ASriano vwater - Bill Stambaugh [Ex. 6 - Personal Privacy] Smith, Art[Smith.Art@epa.gov]; Russell Water - Frank Stephenson[russellwaterplant@gmail.com]; Jeff Vogt[Jeff.Vogt@gcww.cincinnati-oh.gov]; sutherland@post.ci.portsmouth.oh.us[sutherland@post.ci.portsmouth.oh.us]; Mike Eggert[Michael.Eggert@epa.state.oh.us]; Maysville Water[ewenz@maysvilleky.net]; robert.francis@ky.gov[robert.francis@ky.gov]; Maysville Water - Greg England [Ex. 6 - Personal Privacy] Bruce Whitteberry[bruce.whitteberry@gcww.cincinnati-oh.gov]; Roney, Julie (EEC)[Julie.Roney@ky.gov]; Richard.Stuck@gcww.cincinnati-oh.gov[Richard.Stuck@gcww.cincinnati-oh.gov]; Nicole Estes[nestes@lwcky.com]; Ward, Harold D[Harold.D.Ward@wv.gov]; L [Ex. 6 - Personal Privacy] Maysville Water[darrengarrison@maysvilleky.net]; Portsmouth Water[lab@post.ci.portsmouth.oh.us]; Dorsey, Mike H[Mike.H.Dorsey@wv.gov]; H [Ex. 6 - Personal Privacy] Ryan Watts[irononwater@sbcglobal.net]; B [Ex. 6 - Personal Privacy]amwater.com]  
**From:** Jerry Schulte  
**Sent:** Fri 2/14/2014 11:25:09 PM  
**Subject:** RE: Fields Creek Coal Slurry Spill

Thanks Sandy!

On Feb 14, 2014 6:22 PM, <[Ex. 6 - Personal Privacy]> wrote:

On Wednesday evening, the Huntington team went to the Winfield Locks and Dam. We collected samples every hour at this location from 4pm until 10pm . Slight organic odor was noticed and conductivity show some rise during the sampling time.  
Samples were collected and brought back to lab to run GC/MS analysis.

Every sample appeared clear except for one small peak that when compared to earlier samples (in January) was not there. Blanks before and after these samples were negative for this peak.

Unsure if it is anything to be concerned about but I am not able to find any data on it in searches of internet and other databases. I wanted to share in hopes that someone could confirm.  
Library search is attached.

(See attached file: Scan.pdf)

We have began feeding PAC in response to arrival time based on your time calculations and increasing sample collection of raw water.

Sandy

[Ex. 6 - Personal Privacy]  
Supervisor, Water Quality and Environmental Compliance  
Western Division  
West Virginia American Water  
4002 Ohio River Road  
Huntington, WV 25702  
[Ex. 6 - Personal Privacy]

Cell: Ex. 6 - Personal Privacy  
Fax: 304.525.3495  
[sjohnson@wvawater.com](mailto:sjohnson@wvawater.com)

"Life can only be understood backward, but it can only be lived forward"  
-Soren Kierkegaard